

### LAMP CHANGES (first comment period)

Pg. no.	Source	Comments	Accept
2	EH	Table of contents add town of Tenant figure	
9	EH	Town of Tenant added to high density septic area	
10	EH	Tenant & Macdoel added high density with community water	
11	EH	CVRWQCB added with NCRWQCB – water boards of responsibility	
14	EH	Seasonal ground water (language edit)	
15	EH/ BOS	93.2 monitoring: removed collection of data via real-estate sale	
16	EH/ BOS	Added requirement that private well may be tested upon septic system failure and replacement.	
16	EH	In addition to, (language edit)	
20	EH	Update of table 1 to include Macdoel and Tenant	
29	EH	Addition of figure 6 for the town of Tenant	

## OWTS REGULATIONS AND TECHNICAL MANUAL CHANGES

(First comment period)

Pg. no.	Source	Comments	Accept
iii	EH	Acronyms updated	
16	James Bray	Word any replaced with word no to clarify language	
17	EH	Reference to county code	
18	EH	Town of Tenant added to the high OWTS density areas.	
20	EH	Soil groups A & B added to clarify when textural analysis is required for soils when ground water separation is in question	
22	Dan Simons	Clarify: when determining separation to ground water table that the first encountered elevation is to be used rather than the static or stabilized elevation when observed by backhoe excavation.	
22	Dan Simons	Concerns regarding the verification of wet weather perk testing by engineers	
23	EH	Added observation well to clarify.	
25	EH	Table 2 modified to more reader friendly format	
26	EH	Added formula to clarify calculation.	
27	Bray Kellogg	<b>Sidewall use for leach field design/application rate</b>	
45	EH	Updated specific section reference	
53	EH/ BOS	Conditions to allow for like for like waste water flows(home remodels, replacements) to existing septic systems	
59	Duane Eastlick	Requirement for effluent filter for outlet tee	
76	EH	Update appendix G to add Macdoel and Tenant	